



MINIMUM WATER SUPPLY PRESSURE



MINIMUM WATER SUPPLY PRESSURE

CONSTRUCTION AND OPERATIONS - ASSET OPERATIONS

POLICY OBJECTIVES

To provide a reasonable minimum water pressure at the property boundary for consumers.

POLICY STATEMENT

- 1 Unless a specific agreement to the contrary exists, Council will endeavour to provide a minimum water pressure of 12m head with a minimum flow of 0.15 l/sec at the property boundary.
- 2 The boundary water pressure will be determined as that pressure which exists under peak demand conditions and normal operations with the supply reservoir 2/3 full.
- 3 The programming and funding of required works will be considered in the preparation of the budget.

(Min No 1658/93 - 14 December 1993)

(Min No 626/96 - 6 August 1996 - Review of Policies)

(Min No 239/2000 – 24 October 2000 – Review of Policies)

(Min No 214/2005 - 8 March 2005 - Review of Policies)

(Min No 2013/388 - 16 July 2013 - Review of Policies)